



Emergency Declaration Form

EDF-202511-1008

Current Holder: O'Connor, Ryan

Request Status: Sent to Regional Administrator

Created On: 11/4/2025 11:58 AM

Requestor Information

Requestor Name	Wedin, Timothy
Requestor's Supervisor	Gordon, Adam
Requestor Division	Environmental Services
Emergency Title	Golden Valley FM - Emergency Repair

Requestor Details

Describe the nature of the emergency	During construction of a MnDOT retaining wall, Interceptor 7027-1 was damaged. The outer protective coating has been damaged, and there are concerns about the integrity of the exposed pipe.
Explain why this situation is a present, immediate, and existing emergency	The protective coating prevents further deterioration of the forcemain. Failure to repair the coating will result in deterioration of the pipe and failure near an existing highway. The damaged section includes a pipe joint, which if not properly repaired, would result in a failure.
Explain how this emergency does or will affect the health, safety, or welfare of the public or the safety of Metropolitan Council employees or facilities	Failure of the pipe would result in a wastewater spill in the project area near a MnDOT highway. A spill would wash materials out from under the highway, creating a sinkhole in a major highway.
Describe the supplies or services which must be acquired to remedy this emergency, including the estimated cost	Pipeline Contractor. Engineer.
Estimated Cost	2,000,000.00
Contractor Identification	TBD

Approvals

Requestor e-Sign	Wedin, Timothy	Signed Date	11/4/2025
Supervisor e-Sign	Gordon, Adam	Signed Date	11/4/2025
Division Director / General Manager e-Sign	Thompson, Leisa	Signed Date	11/4/2025



Emergency Declaration Form

EDF-202511-1008

Regional Administrator e-Sign		Signed Date	
Assigner e-Sign		Signed Date	
Contract Manager / Purchasing Agent			

Comments