



Business Item: 2025-305

Ratification of Declaration of Emergency Repair
of Plymouth Interceptor 7027-1



Environment Committee: January 13, 2026

Chris Remus

Emergency Declaration Process




Emergency Declaration Process

- Infrastructure concern identified and investigated
- Determination made that carrying out the competitive bidding process prescribed by the Council's Procurement Policy would unacceptably delay the commencement of work to repair the facility
- Emergency Declaration document is prepared and signed by the General Manager, Environmental Services
- After review, the Emergency Declaration is authorized by the Regional Administrator, who has delegated authority pursuant to the Council's Procurement Policy.
- Contractor is selected and work begins under the direction of a Council Authorized Representative
- Emergency Declaration is ratified by Metropolitan Council, if the cost to correct the emergency exceeds \$175,000

Emergency Summary and Location

Background

- During recent construction of a MnDOT retaining wall, Interceptor 7027-1 was damaged
- Impacts include damage to the exterior coating, cathodic protection system, and a pipe joint.
- Impact will need to be repaired or evaluated if the pipe can continue to provide long-term service in its current condition.
- Interceptor 7207-1 will be dewatered to investigate for further damage.



Project Photos

Inspection photos of Interceptor 7027-1



Proposed Action



That the Metropolitan Council ratify the Emergency Declaration for repairs to Interceptor 7027-1 in Golden Valley in an amount not to exceed \$2,000,000.



Q
uest
ions

Chris Remus

Assistant Manager, Interceptor Engineering
christopher.remus@metc.state.mn.us
651-602-4538

